

# Nordic Reactor Safety Related Progress

Joint NKS-R and NKS-B Seminar,  
Stockholm, 12-13 January 2016

Tomi Routamo

Photo: TEPCO



Total deposition of Cs-134 and Cs-137 (Bq/m<sup>2</sup>)  
[Converted into the value as of April 29]

- 3,000,000 - 30,000,000
- 1,000,000 - 3,000,000
- 600,000 - 1,000,000
- 300,000 - 600,000
- < 300,000
- Areas where readings were not obtained
- Fukushima Dai-ichi NPP

5 mSv  
10 mSv  
20km  
30km  
60km  
80km

白河市 角田市 新地町 相馬市 双葉町 大熊町 富岡町 楮葉町 広野町 北茨城市 高萩市 白河町 古殿町 いわき市 田村市 川内村 二本松市 本宮市 郡山市 須賀川市 猪苗代町 米沢市 国見町 桑折町 伊達市 川俣町 飯館村 川俣町 飯館村 川俣町 飯館村

# Fukushima Dai-ichi accident 11 March 2011

- Concerns about safety of NPPs in Europe
- Stress Tests initiated in June 2011
  - Flooding
  - Earthquake
  - Extreme weather conditions
  - Robustness against loss of AC power and loss of ultimate heat sink
  - Severe accident management
- Followed by Peer Reviews and developing National Action Plans to improve nuclear safety in Europe



# General situation in Finland (prior to the Fukushima Dai-ichi accident)

- Comprehensive PSA studies
  - Natural hazards included in the studies
  - No significant deficiencies arose from the Stress Tests
  - Some aspects re-evaluated based on National Safety Review
    - high sea water level (Loviisa), total loss of AC power (Olkiluoto), loss of sea as a heat sink (Loviisa & Olkiluoto), loss of fuel pool cooling (Loviisa & Olkiluoto)
- Severe accident management
  - Required in Finnish regulatory framework since 1980's
  - Implementation in 1980's and 1990's in existing plants
  - Taken into account in the design of new plants (including OL3)
  - Only minor changes due to lessons learnt from the Fukushima Dai-ichi accident
    - Emergency preparedness in case of multi-unit accidents
  - Situation in Sweden rather similar to that in Finland

# Major safety enhancements in Finnish plants

- Protection against extremely high sea level in (Loviisa 1&2)
  - At Olkiluoto site the flooding risk is lower
- Reducing the reactor cooling dependency on AC power (Olkiluoto 1&2)
  - Independent diesel driven auxiliary feed water pumping station at Loviisa
- Reducing the heat removal dependency on sea water systems (Loviisa 1&2 and Olkiluoto 1&2)
- Improving fuel pool cooling capabilities (water injection, monitoring) (Loviisa 1&2, Olkiluoto 1&2, Olkiluoto 3)
- Ensuring emergency preparedness in case of multi-unit events

# Olkiluoto 1 & 2:

## Steam turbine driven auxiliary feed water pump

SEP 13-061 Appendix 1  
Page 1 (1)

Flow diagram sketch of ACIS, system 329





Figure: TVO

Flow diagram sketch of ACIS, system 329

# Olkiluoto 1 & 2: Changes in 327 (auxiliary feed water system)


Original arrangement when  
pumps are started but  
water is not injected into  
the reactor

- Recirculation through  
a closed loop
- Requires seawater cooling



New arrangement

- Recirculation through  
demineralized water tank
- High heat capacity  
of the tank
- No cooling needed for a  
long time



# Olkiluoto 1 & 2:

## Fire water injection into fuel pools

Connection outside  
the reactor building



Photos: TVO



# Olkiluoto 1 & 2:

## Fire water injection into fuel pools

Connections inside  
the reactor building



Photos: TVO

# Olkiluoto 1 & 2:

## Fire water injection into fuel pools

Entry into the pool



Photos: TVO

# Olkiluoto - Spent fuel storage: Fire water injection into fuel pools

Fire  
water  
hose




Photo: TVO



# Olkiluoto 1 & 2:

## Fuel pool instrumentation

Water level measurement device



Photos: TVO



# Loviisa 1 & 2

## Diversification of heat removal



Photos: Fortum



# Loviisa 1 & 2 – Diversification of heat removal



Photo: STUK



# Loviisa 1 & 2: Diversification of heat removal



Photo: STUK

10/08/2015



Photo: Fortum




Photo: STUK

10/08/2015



# Loviisa 1 & 2: Flooding protection (diesel driven auxiliary emergency feed water pumping station)





# Loviisa 1 & 2

## Flooding protection

(diesel driven auxiliary emergency feed water pumping station)



# Approaches in Sweden and in Finland

SSM Independent Core Cooling (SSM2014-122-6 )	STUK YVL Guides (published in Nov 2013)
Rather strict independence from other safety systems	Existing equipment can be credited Mobile equipment not preferred
	Loss of power distribution system (not combined with other extreme events)
Can be considered as a separate level of Defence-in-Depth	DEC-situations as part of level 3 of DiD
Safety margins based on considerable uncertainties	Realistic assumptions can be used in DEC situations
Very robust approach	Case by case approach
No single failure criterion	
Need to guarantee that additional provisions are effective in expected conditions during situations they are credited	
Site autonomy of 72 h	

# WENRA RHWG work after Fukushima accident

## More insights on WENRA Safety Objectives for new NPPs

- O1. Normal operation, abnormal events and prevention of accidents
- O2. Accidents without core melt
- O3. Accidents with core melt
- O4. Independence between all levels of DiD
- O5. Safety and security interfaces
- O6. Radiation protection and waste management
- O7. Leadership and management for safety

# WENRA RHWG work after Fukushima accident

## Selected key safety issues for new NPPs

- Position 1: DiD approach for new nuclear power plants
- Position 2: Independence of the levels of DiD
- Position 3: Multiple failure events
- Position 4: Provisions to mitigate core melt and radiological consequences
- Position 5: Practical elimination
- Position 6: External Hazards
- Position 7: Intentional crash of a commercial airplane

WENRA RHWG report “Safety of new NPP designs” in March 2013

([www.wenra.org/archives/wenra-statement-report-new-NPP](http://www.wenra.org/archives/wenra-statement-report-new-NPP))



# WENRA RHWG work after Fukushima accident

## Safety Reference Levels for Existing NPPs

Taking into account Fukushima lessons learnt  
in WENRA Reference Levels

- Major changes in
  - Issue E “Design Basis Envelope”
  - Issue F “Design Extension” (includes severe accidents)
  - Issue LM “EOPs and SAMGs”
  - Issue R “On-site Emergency Preparedness”
  - Issue T “Natural Hazards” (new issue)
- Some changes in issues A, B, C, D, G, N, O, P, S
  - Safety culture under C7 (RLs C7.1, C7.2, C7.3)
- Published in September 2014 ([www.wenra.org/archives/wenra\\_srl](http://www.wenra.org/archives/wenra_srl))

# Changes in Finnish regulatory framework

## Updated Government Decrees in 2013

- Safety of NPPs (717/2013)
- Emergency Preparedness of NPPs (716/2013)
- these were replaced by STUK Regulations in the beginning of 2016

(In Finnish: <http://www.finlex.fi/fi/viranomaiset/normi/555001/>; In Swedish: <http://www.finlex.fi/sv/viranomaiset/normi/555001/>)

## Update of all of the YVL Guides (renewal project)

- Published in November 2013

## The above work was ongoing already pre-Fukushima

- The accident delayed the work
- Lessons learnt were taken into account

## DiD concept was not found to have such weaknesses that a thorough revision should take place

- Extreme natural hazards have been addressed in more detail as DEC

# WENRA RHWG work after Fukushima accident

## Implementation of revised Safety Reference Levels for Existing NPPs

STUK and SSM are actively participating in RHWG work

Self assessments of implementation status (October 2015)

- No significant gaps in YVL guides
- In Sweden somewhat wider revision of regulation is needed

Peer review of self assessments in 2016

- In three RHWG meetings (Jan, May, Sep)
- The results from these will finally set the implementation status

Implementation of the new RLs should take place in 2017 at latest

- National implementation plans required

Thank you